



1'- 0" MIN DI SPOOL PE
1'- 6" MAX (TYP)

MJ GATE VALVE 8" AND SMALLER
MJ BUTTERFLY VALVE 10" AND LARGER
UNLESS APPROVED BY CITY ENGINEER

800' MAX.

SEE OTHER DETAILS FOR VALVE BOX
AND SETTING REQUIRMENTS